

Report To: Pete Obrien

Company: Boulder Water Well Service
1901 S 120th Street
Suite A
Lafayette CO 80026

Bill To: Accounts Payable

Company: Boulder Water Well Service
1901 S 120th Street
Suite A
Lafayette CO 80026

Task No.: 220103054

Client PO:

Client Project: East Boulder County WD CO0107236

Date Received: 1/3/22

Date Reported: 1/4/22

Matrix: Water - Drinking

Customer Sample ID 7555 Spring Dr.

Sample Date/Time: 1/3/22 1:15 PM

Lab Number: 220103054-01

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
1,1,1,2-Tetrachloroethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,1,1-Trichloroethane	ND	EPA-524.2	0.5 ug/L	200	1/3/22	QC54188	LEH
1,1,2,2-Tetrachloroethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,1,2-Trichloroethane	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
1,1-Dichloroethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,1-Dichloroethylene	ND	EPA-524.2	0.5 ug/L	7	1/3/22	QC54188	LEH
1,1-Dichloropropene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,2,3-Trichlorobenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,2,3-Trichloropropane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,2,4-Trichlorobenzene	ND	EPA-524.2	0.5 ug/L	70	1/3/22	QC54188	LEH
1,2,4-Trimethylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,2-Dichloroethane	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
1,2-Dichloropropane	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
1,3,5-Trimethylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,3-Dichloropropane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
1,3-Dichloropropene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Benzene	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
Bromobenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Bromochloromethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Bromodichloromethane	11.8 ug/L	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Bromoform	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Bromomethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Carbon Tetrachloride	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Pete Obrien

Company: Boulder Water Well Service
1901 S 120th Street
Suite A
Lafayette CO 80026

Bill To: Accounts Payable

Company: Boulder Water Well Service
1901 S 120th Street
Suite A
Lafayette CO 80026

Task No.: 220103054	Date Received: 1/3/22
Client PO:	Date Reported: 1/4/22
Client Project: East Boulder County WD CO0107236	Matrix: Water - Drinking

Customer Sample ID 7555 Spring Dr.
Sample Date/Time: 1/3/22 1:15 PM
Lab Number: 220103054-01

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
Chlorodibromomethane	3.9 ug/L	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Chloroethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Chloroform	27.9 ug/L	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Chloromethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
cis-1,2-Dichloroethylene	ND	EPA-524.2	0.5 ug/L	70	1/3/22	QC54188	LEH
Dibromomethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Dichlorodifluoromethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Dichloromethane	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
Ethylbenzene	ND	EPA-524.2	0.5 ug/L	700	1/3/22	QC54188	LEH
Fluorotrichloromethane	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Hexachlorobutadiene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Isopropylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
m-Dichlorobenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Monochlorobenzene	ND	EPA-524.2	0.5 ug/L	100	1/3/22	QC54188	LEH
Naphthalene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
n-Butylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
n-Propylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
o-Chlorotoluene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
o-Dichlorobenzene	ND	EPA-524.2	0.5 ug/L	600	1/3/22	QC54188	LEH
Para-Dichlorobenzene	ND	EPA-524.2	0.5 ug/L	75	1/3/22	QC54188	LEH
p-Chlorotoluene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
p-Isopropyltoluene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
sec-Butylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Analytical Results

TASK NO: 220103054

Report To: Pete Obrien
Company: Boulder Water Well Service
1901 S 120th Street
Suite A
Lafayette CO 80026

Bill To: Accounts Payable
Company: Boulder Water Well Service
1901 S 120th Street
Suite A
Lafayette CO 80026

Task No.: 220103054
Client PO:
Client Project: East Boulder County WD CO0107236
Date Received: 1/3/22
Date Reported: 1/4/22
Matrix: Water - Drinking

Customer Sample ID 7555 Spring Dr.
Sample Date/Time: 1/3/22 1:15 PM
Lab Number: 220103054-01

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
Styrene	ND	EPA-524.2	0.5 ug/L	100	1/3/22	QC54188	LEH
tert-Butylbenzene	ND	EPA-524.2	0.5 ug/L		1/3/22	QC54188	LEH
Tetrachloroethylene	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
Toluene	ND	EPA-524.2	0.5 ug/L	1000	1/3/22	QC54188	LEH
Total Trihalomethanes	43.6 ug/L	EPA-524.2	0.5 ug/L	80	1/3/22	QC54188	LEH
trans-1,2-Dichloroethylene	ND	EPA-524.2	0.5 ug/L	100	1/3/22	QC54188	LEH
Trichloroethylene	ND	EPA-524.2	0.5 ug/L	5	1/3/22	QC54188	LEH
Vinyl chloride	ND	EPA-524.2	0.5 ug/L	2	1/3/22	QC54188	LEH
Xylenes (total)	ND	EPA-524.2	0.5 ug/L	10000	1/3/22	QC54188	LEH

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Report To: Pete Obrien
Company: Boulder Water Well Service

Receive Date: 1/3/22
Project Name: East Boulder County WD CO0107236

Test	QC Batch ID	QC Type	Result	Method
1,1,1,2-Tetrachloroethane	QC54188	Method Blank	ND	EPA-524.2
1,1,1-Trichloroethane	QC54188	Method Blank	ND	EPA-524.2
1,1,2,2-Tetrachloroethane	QC54188	Method Blank	ND	EPA-524.2
1,1,2-Trichloroethane	QC54188	Method Blank	ND	EPA-524.2
1,1-Dichloroethane	QC54188	Method Blank	ND	EPA-524.2
1,1-Dichloroethylene	QC54188	Method Blank	ND	EPA-524.2
1,1-Dichloropropene	QC54188	Method Blank	ND	EPA-524.2
1,2,3-Trichlorobenzene	QC54188	Method Blank	ND	EPA-524.2
1,2,3-Trichloropropane	QC54188	Method Blank	ND	EPA-524.2
1,2,4-Trichlorobenzene	QC54188	Method Blank	ND	EPA-524.2
1,2,4-Trimethylbenzene	QC54188	Method Blank	ND	EPA-524.2
1,2-Dichloroethane	QC54188	Method Blank	ND	EPA-524.2
1,2-Dichloropropane	QC54188	Method Blank	ND	EPA-524.2
1,3,5-Trimethylbenzene	QC54188	Method Blank	ND	EPA-524.2
1,3-Dichloropropane	QC54188	Method Blank	ND	EPA-524.2
1,3-Dichloropropene	QC54188	Method Blank	ND	EPA-524.2
Benzene	QC54188	Method Blank	ND	EPA-524.2
Bromobenzene	QC54188	Method Blank	ND	EPA-524.2
Bromochloromethane	QC54188	Method Blank	ND	EPA-524.2
Bromodichloromethane	QC54188	Method Blank	ND	EPA-524.2
Bromoform	QC54188	Method Blank	ND	EPA-524.2
Bromomethane	QC54188	Method Blank	ND	EPA-524.2
Carbon Tetrachloride	QC54188	Method Blank	ND	EPA-524.2
Chlorodibromomethane	QC54188	Method Blank	ND	EPA-524.2
Chloroethane	QC54188	Method Blank	ND	EPA-524.2
Chloroform	QC54188	Method Blank	ND	EPA-524.2
Chloromethane	QC54188	Method Blank	ND	EPA-524.2
cis-1,2-Dichloroethylene	QC54188	Method Blank	ND	EPA-524.2
Dibromomethane	QC54188	Method Blank	ND	EPA-524.2
Dichlorodifluoromethane	QC54188	Method Blank	ND	EPA-524.2
Dichloromethane	QC54188	Method Blank	ND	EPA-524.2
Ethylbenzene	QC54188	Method Blank	ND	EPA-524.2
Fluorotrichloromethane	QC54188	Method Blank	ND	EPA-524.2
Hexachlorobutadiene	QC54188	Method Blank	ND	EPA-524.2
Isopropylbenzene	QC54188	Method Blank	ND	EPA-524.2
m-Dichlorobenzene	QC54188	Method Blank	ND	EPA-524.2
Monochlorobenzene	QC54188	Method Blank	ND	EPA-524.2
Naphthalene	QC54188	Method Blank	ND	EPA-524.2
n-Butylbenzene	QC54188	Method Blank	ND	EPA-524.2
n-Propylbenzene	QC54188	Method Blank	ND	EPA-524.2
o-Chlorotoluene	QC54188	Method Blank	ND	EPA-524.2

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

o-Dichlorobenzene	QC54188	Method Blank	ND	EPA-524.2
Para-Dichlorobenzene	QC54188	Method Blank	ND	EPA-524.2
p-Chlorotoluene	QC54188	Method Blank	ND	EPA-524.2
p-Isopropyltoluene	QC54188	Method Blank	ND	EPA-524.2
sec-Butylbenzene	QC54188	Method Blank	ND	EPA-524.2
Styrene	QC54188	Method Blank	ND	EPA-524.2
tert-Butylbenzene	QC54188	Method Blank	ND	EPA-524.2
Tetrachloroethylene	QC54188	Method Blank	ND	EPA-524.2
Toluene	QC54188	Method Blank	ND	EPA-524.2
Total Trihalomethanes	QC54188	Method Blank	ND	EPA-524.2
trans-1,2-Dichloroethylene	QC54188	Method Blank	ND	EPA-524.2
Trichloroethylene	QC54188	Method Blank	ND	EPA-524.2
Vinyl chloride	QC54188	Method Blank	ND	EPA-524.2
Xylenes (total)	QC54188	Method Blank	ND	EPA-524.2

Test	QC Batch ID	QC Type	Limits	% Rec	RPD	Method
1,1,1,2-Tetrachloroethane	QC54188	LCS	70 - 130	93.4	-	EPA-524.2
		LCS Dup	70 - 130	89.4	-	
1,1,1-Trichloroethane	QC54188	LCS	70 - 130	101.4	-	EPA-524.2
		LCS Dup	70 - 130	91.0	-	
1,1,2,2-Tetrachloroethane	QC54188	LCS	70 - 130	99.4	-	EPA-524.2
		LCS Dup	70 - 130	97.0	-	
1,1,2-Trichloroethane	QC54188	LCS	70 - 130	107.4	-	EPA-524.2
		LCS Dup	70 - 130	100.0	-	
1,1-Dichloroethane	QC54188	LCS	70 - 130	101.0	-	EPA-524.2
		LCS Dup	70 - 130	96.6	-	
1,1-Dichloroethylene	QC54188	LCS	70 - 130	104.8	-	EPA-524.2
		LCS Dup	70 - 130	94.4	-	
1,1-Dichloropropene	QC54188	LCS	70 - 130	93.8	-	EPA-524.2
		LCS Dup	70 - 130	91.2	-	
1,2,3-Trichlorobenzene	QC54188	LCS	70 - 130	92.2	-	EPA-524.2
		LCS Dup	70 - 130	89.0	-	
1,2,3-Trichloropropane	QC54188	LCS	70 - 130	107.4	-	EPA-524.2
		LCS Dup	70 - 130	101.2	-	
1,2,4-Trichlorobenzene	QC54188	LCS	70 - 130	95.4	-	EPA-524.2
		LCS Dup	70 - 130	86.8	-	
1,2,4-Trimethylbenzene	QC54188	LCS	70 - 130	103.2	-	EPA-524.2
		LCS Dup	70 - 130	97.4	-	
1,2-Dichloroethane	QC54188	LCS	70 - 130	100.2	-	EPA-524.2
		LCS Dup	70 - 130	97.0	-	
1,2-Dichloropropane	QC54188	LCS	70 - 130	98.4	-	EPA-524.2
		LCS Dup	70 - 130	96.0	-	
1,3,5-Trimethylbenzene	QC54188	LCS	70 - 130	100.8	-	EPA-524.2
		LCS Dup	70 - 130	95.4	-	
1,3-Dichloropropane	QC54188	LCS	70 - 130	106.4	-	EPA-524.2
		LCS Dup	70 - 130	103.2	-	
Benzene	QC54188	LCS	70 - 130	99.6	-	EPA-524.2
		LCS Dup	70 - 130	91.2	-	
Bromobenzene	QC54188	LCS	70 - 130	103.2	-	EPA-524.2
		LCS Dup	70 - 130	100.8	-	
Bromochloromethane	QC54188	LCS	70 - 130	92.6	-	EPA-524.2
		LCS Dup	70 - 130	87.6	-	

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Test	QC Batch ID	QC Type	Limits	% Rec	RPD	Method
Bromodichloromethane	QC54188	LCS	70 - 130	88.0	-	EPA-524.2
		LCS Dup	70 - 130	81.4	-	
Bromoform	QC54188	LCS	70 - 130	81.8	-	EPA-524.2
		LCS Dup	70 - 130	75.8	-	
Bromomethane	QC54188	LCS	70 - 130	109.8	-	EPA-524.2
		LCS Dup	70 - 130	99.2	-	
Carbon Tetrachloride	QC54188	LCS	70 - 130	94.4	-	EPA-524.2
		LCS Dup	70 - 130	91.2	-	
Chlorodibromomethane	QC54188	LCS	70 - 130	86.6	-	EPA-524.2
		LCS Dup	70 - 130	81.0	-	
Chloroethane	QC54188	LCS	70 - 130	113.2	-	EPA-524.2
		LCS Dup	70 - 130	108.2	-	
Chloroform	QC54188	LCS	70 - 130	101.2	-	EPA-524.2
		LCS Dup	70 - 130	96.2	-	
Chloromethane	QC54188	LCS	70 - 130	97.4	-	EPA-524.2
		LCS Dup	70 - 130	86.4	-	
cis-1,2-Dichloroethylene	QC54188	LCS	70 - 130	88.8	-	EPA-524.2
		LCS Dup	70 - 130	83.0	-	
Dibromomethane	QC54188	LCS	70 - 130	101.4	-	EPA-524.2
		LCS Dup	70 - 130	100.0	-	
Dichlorodifluoromethane	QC54188	LCS	70 - 130	110.0	-	EPA-524.2
		LCS Dup	70 - 130	107.6	-	
Dichloromethane	QC54188	LCS	70 - 130	108.6	-	EPA-524.2
		LCS Dup	70 - 130	105.8	-	
Ethylbenzene	QC54188	LCS	70 - 130	104.8	-	EPA-524.2
		LCS Dup	70 - 130	97.6	-	
Fluorotrichloromethane	QC54188	LCS	70 - 130	114.6	-	EPA-524.2
		LCS Dup	70 - 130	98.8	-	
Hexachlorobutadiene	QC54188	LCS	70 - 130	85.0	-	EPA-524.2
		LCS Dup	70 - 130	84.6	-	
Isopropylbenzene	QC54188	LCS	70 - 130	106.8	-	EPA-524.2
		LCS Dup	70 - 130	100.4	-	
m-Dichlorobenzene	QC54188	LCS	70 - 130	109.4	-	EPA-524.2
		LCS Dup	70 - 130	102.0	-	
Monochlorobenzene	QC54188	LCS	70 - 130	108.8	-	EPA-524.2
		LCS Dup	70 - 130	103.0	-	
Naphthalene	QC54188	LCS	70 - 130	97.0	-	EPA-524.2
		LCS Dup	70 - 130	92.6	-	
n-Butylbenzene	QC54188	LCS	70 - 130	106.8	-	EPA-524.2
		LCS Dup	70 - 130	101.0	-	
n-Propylbenzene	QC54188	LCS	70 - 130	110.4	-	EPA-524.2
		LCS Dup	70 - 130	102.6	-	
o-Chlorotoluene	QC54188	LCS	70 - 130	102.6	-	EPA-524.2
		LCS Dup	70 - 130	96.8	-	
o-Dichlorobenzene	QC54188	LCS	70 - 130	105.0	-	EPA-524.2
		LCS Dup	70 - 130	97.0	-	
Para-Dichlorobenzene	QC54188	LCS	70 - 130	106.4	-	EPA-524.2
		LCS Dup	70 - 130	98.8	-	
p-Chlorotoluene	QC54188	LCS	70 - 130	106.0	-	EPA-524.2
		LCS Dup	70 - 130	99.4	-	

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
ND = Not Detected at Reporting Limit.

Test	QC Batch ID	QC Type	Limits	% Rec	RPD	Method
p-Isopropyltoluene	QC54188	LCS	70 - 130	106.4	-	EPA-524.2
		LCS Dup	70 - 130	99.2	-	
sec-Butylbenzene	QC54188	LCS	70 - 130	115.4	-	EPA-524.2
		LCS Dup	70 - 130	107.2	-	
Styrene	QC54188	LCS	70 - 130	105.0	-	EPA-524.2
		LCS Dup	70 - 130	100.4	-	
tert-Butylbenzene	QC54188	LCS	70 - 130	107.0	-	EPA-524.2
		LCS Dup	70 - 130	97.8	-	
Tetrachloroethylene	QC54188	LCS	70 - 130	101.8	-	EPA-524.2
		LCS Dup	70 - 130	99.8	-	
Toluene	QC54188	LCS	70 - 130	102.4	-	EPA-524.2
		LCS Dup	70 - 130	94.0	-	
trans-1,2-Dichloroethylene	QC54188	LCS	70 - 130	99.2	-	EPA-524.2
		LCS Dup	70 - 130	96.8	-	
Trichloroethylene	QC54188	LCS	70 - 130	97.2	-	EPA-524.2
		LCS Dup	70 - 130	87.6	-	
Vinyl chloride	QC54188	LCS	70 - 130	101.4	-	EPA-524.2
		LCS Dup	70 - 130	97.6	-	

All analyses were performed in accordance with approved methods under the latest revision to 40 CFR Part 136 unless otherwise identified. Based on my inquiry of the person or persons directly responsible for analyzing the wastewater samples and generating the report (s), the analyses, report, and information submitted are, to the best of my knowledge and belief, true, accurate, and complete.



DATA APPROVED FOR RELEASE BY

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
 mg/L = Milligrams Per Liter or PPM
 ug/L = Micrograms Per Liter or PPB
 mpn/100 mls = Most Probable Number Index/ 100 mls
 Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
 (s) Spike amount low relative to the sample amount.
 ND = Not Detected at Reporting Limit.

Drinking Water Chain of Custody



Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information		Bill To Information (If different from report to)		Project Information	
Company Name: <u>BWL</u>		Company Name: _____		PWSID: <u>107234</u>	
Contact Name: <u>Pete</u>		Contact Name: _____		System Name: <u>EBCW</u>	
Address: <u>1901 S. 120th St. Ste A</u>		Address: _____		Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
City: <u>Lafayette</u> State: <u>CO</u> Zip: <u>80028</u>		City: <u>Stam</u> State: _____ Zip: _____		Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Phone: <u>303-442-191</u>		Phone: _____		Task Number (Lab Use Only)	
Email: <u>office@waterwell.co</u>		Email: _____		CAL Task	
Sample Collector: <u>Pete</u>		Sample Collector: _____		220103054	
Sample Collector Phone: <u>303 519-4462</u>		PO Number: _____		JAK	

PHASE I, II, V Drinking Water Analyses (check requested analysis)

Subcontract Analyses

Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothal	549.2 Diquat	524.2 THMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite
1-3-22	13:15	7555 Spring Dr	3						X																				
1-3-22	13:55	1027 Paragon Dr	1	1.01	X																								
1-3-22	14:20	841 Paragon Dr	1	1.21	X																								
1-3-22	13:20	7555 Spring Dr	1	1.05	X																								
1-3-22	12:00	7560 Paragon Dr	1	1.18	X																								
			7	blank																									

Instructions: <u>* 2 DAY TAT ON VOCs *</u>				C/S Info: _____				Seals Present Yes <input type="checkbox"/> No <input type="checkbox"/> Headspace Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>							
Relinquished By: <u>[Signature]</u>		Date/Time: <u>1-3-22 7:18</u>		Received By: <u>[Signature]</u>		Date/Time: <u>1/3/22</u>		Delivered Via: <u>HO</u>		C/S Charge <input type="checkbox"/>		Temp: <u>8</u> C/Ice <u>Y</u>		Sample Pres. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	