



Colorado Department  
of Public Health  
and Environment

**Total Trihalomethane Certified Laboratory Report Form**  
**WQCD - Drinking Water CAS**  
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

**TTHM**

Section I (to be completed by the Public Water Systems only)				Section II (to be completed by Laboratories only)			
Public Water System Information				Laboratory Information			
PWSID#: CO0107236		Facility ID: DS001		Laboratory ID: CO015			
System Name: East Boulder County WD				Laboratory Name: Colorado Analytical Laboratory			
Contact Person: Pete Obrien		Phone #: 303-442-1911		Contact Person: Customer Service		Phone: 303-659-2313	
Comments:				Comments:			

Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
2/8/23		635 Paragon	2/8/23	2/11/23	230208217-01A	Chloroform	EPA-524.2	N/A	0.5	17.92
						Bromoform	EPA-524.2	N/A	0.5	BDL
						Bromodichloromethane	EPA-524.2	N/A	0.5	8.87
						Dibromochloromethane	EPA-524.2	N/A	0.5	2.51
						Total Trihalomethanes	EPA-524.2	80	0.5	29.3
2/8/23		Tank In	2/8/23	2/11/23	230208217-02A	Chloroform	EPA-524.2	N/A	0.5	17.13
						Bromoform	EPA-524.2	N/A	0.5	BDL
						Bromodichloromethane	EPA-524.2	N/A	0.5	8.85
						Dibromochloromethane	EPA-524.2	N/A	0.5	2.54
						Total Trihalomethanes	EPA-524.2	80	0.5	28.5
2/8/23		Tank Out	2/8/23	2/11/23	230208217-03A	Chloroform	EPA-524.2	N/A	0.5	25.66
						Bromoform	EPA-524.2	N/A	0.5	BDL
						Bromodichloromethane	EPA-524.2	N/A	0.5	10.79
						Dibromochloromethane	EPA-524.2	N/A	0.5	2.96
						Total Trihalomethanes	EPA-524.2	80	0.5	39.4

NT: Not Tested  
Lab MRL: Laboratory Minimum Reporting Level  
BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter  
MCL: Maximum Contaminant Level

2/22/23  
230208217  
1/1  
N

