



Colorado Department
of Public Health
and Environment

Total Trihalomethane Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

TTHM

Section I (to be completed by the Public Water Systems only)					Section II (to be completed by Laboratories only)					
Public Water System Information					Laboratory Information					
PWSID#: CO0107236			Facility ID: DS001		Laboratory ID: CO015					
System Name: East Boulder County WD					Laboratory Name: Colorado Analytical Laboratory					
Contact Person: Pete Obrien			Phone #: 303-442-1911		Contact Person: Customer Service			Phone: 303-659-2313		
Comments:					Comments:					
Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
11/9/23	DBP002	DBP002	11/9/23	11/13/23	231109129-01A	Chloroform	EPA-524.2	N/A	0.5	61.61
						Bromoform	EPA-524.2	N/A	0.5	BDL
						Bromodichloromethane	EPA-524.2	N/A	0.5	17.57
						Dibromochloromethane	EPA-524.2	N/A	0.5	4.29
						Total Trihalomethanes	EPA-524.2	80	0.5	83.5

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter
MCL: Maximum Contaminant Level

11/21/23
231109129
1/1
Y

